

# Future Plant Portfolio


## Cost Comparison

04-Oct-2007

# Balanced systems?



Transport fleet for  
retail/wholesale drinks co.



Lowest cost per unit  
weight transported

Shortest transport time

Systems which satisfy  
multiple objectives by  
providing a **range** of  
functionality.

# What are we doing?




- Assuming demand growth and generation closures
  - evaluate the costs associated with a number of potential portfolio expansion options.
  
- Initially this study will look at RoI portfolio expansion
  - prior to commissioning of the East West interconnector

# Study objectives



- Provide fiscal information related to meeting customer demand
  - Capital
  - Fuel
  - O&M
  - CO<sub>2</sub>
- Options can be compared on this basis



- Study will determine the relative generation costs of Portfolio A
- Can be used to evaluate fit with other criteria

# Disclaimer










- A reasonable set of assumptions made on capital cost, fuel prices etc. to inform debate
  - Not 'the' definitive list
- Generator revenue and profit not examined
  - the focus is on total system cost evaluation.

# The candidates


Different types of new plant will be considered:

- OCGTs
- CCGTs
- Coal-burning plant
- Diesel unit
- Biomass
- Pumped-storage


# The Details

Plant Additions	MW	$\eta$ at MCR (%)	Avail. (%)
  11 x 30 MW Diesel units	330	46.1	96.0
 4 x 93 MW LMS100 units	372	43.3	94.2
 1 x 400 MW Fluidised Bed Steam	400	42.5	87.6
 1 x 389 MW CCGT (BNE)	389	54.7	92.3
 3 x 115 MW CCGTs	345	53.1	92.3
 9 x 41 MW OCGTs	369	39.0	94.2
 2 x 182 MW OCGTs	364	33.3	94.2
 2 x 157 MW OCGTs	314	33.5	92.3
4 x 273 MW P.S. units	1092	76.0	93.3
12 x 30 MW grate-based biomass units	360	28.0	87.6

# Annualised Capital Cost (relative to the cheapest option)



# Fixed O&M Cost (relative to the cheapest option)



# Simulation Studies

Simulation studies were carried out using  
**PROMOD**

- All-Island generation dispatch
- Allowing for 1300 MW plant closure
- 2 x 430 MW new CCGTs commissioned
- Including 3100 MW of wind.

The two principal results of interest were:


- Total system fuel cost;
- CO<sub>2</sub> Volume.

## Fuel Prices (Central scenario)

<b>Fuel</b>	<b>Price (€cent / net GJ)</b>
Coal [RoI, NI]	188, 223
Gas	Min to Max: 553 (Aug) to 844 (Jan)
Heavy Fuel Oil	573
Distillate Oil [RoI, NI]	1074, 943
Peat	349
Miscanthus	500


Gas prices expressed in €cent / gross therm: 52.6 (Aug) to 80.2 (Jan)

# Fuel Prices from Pöyry (All scenarios)




# Fuel Cost at MCR (€/MWh)


[Central scenario; Gas prices at January values]



# System Fuel Cost (relative to the cheapest option) [Central fuel price scenario]



# System CO<sub>2</sub> Cost (relative to the cheapest option)




\* Cost of CO<sub>2</sub> credits assumed to be 30 €/ tonne.

# Overall Cost

The overall cost was calculated by adding the four components:

- Annualised Capital Cost (relative to cheapest);
- Annual Fixed O&M cost (relative to cheapest);
- Annual system fuel cost (relative to cheapest);
- Annual CO<sub>2</sub> cost (relative to cheapest).

# Overall Cost (Base Case)




# Sensitivity Studies


The following sensitivity studies were carried out:

1. High fuel price scenario;
2. Low fuel price scenario;
3. Increased CO<sub>2</sub> cost (from 30 to 100 €/tonne)
4. Higher capacity requirement


# 1. High Fuel Price Scenario




## 2. Low Fuel Price Scenario



### 3. CO2 Cost = 100 €/tonne



# 4. Higher Capacity Requirement




## Summary of Results

(1 = cheapest, ... 10 = most expensive)

Candidate Plant	Central Fuel Prices	High Fuel Prices	Low Fuel Prices	CO <sub>2</sub> = 100 €/tonne (rather than 30)	Higher Capacity
157MW OCGTs	1	1	1	4	2
93MW LMS100 OCGTs	2	2	2	3	1
389MW BNE CCGT	4	3	4	1	3
182MW OCGTs	3	5	3	6	6
115MW CCGTs	6	7	6	2	4
30MW Diesel Units	5	6	7	5	7
41MW OCGTs	7	8	5	7	5
400MW Coal FBS Unit	8	4	9	10	8
1092MW pumped storage	9	9	8	9	
30MW Grate-based Biomass Units	10	10	10	8	

# Example running regimes

# Annual Duration Curve for 157 MW OCGT




Generator	157 MW OCGT burning gas. Min load = 94.2 MW (60% of max).
Capacity Factor	7%
Run Hours	814 (9% of the time)
Running Load Factor	77%
Startups	136 p.a. (1 startup every 2.7 days on average).
Onload Duration	Average of 6.0 hours from startup to shutdown.



Ref: CndPt147


www.eirgrid.com

# Annual Duration Curve for Fluidised Bed Steam unit




Generator	400 MW Fluidised Bed Steam unit burning coal. Min load = 160.0 MW (40% of max).
Capacity Factor	86%
Run Hours	7,679 (88% of the time)
Running Load Factor	98%
Startups	13 p.a. (1 startup every 28 days on average).
Onload Duration	Average of 25 days from startup to shutdown.

# Annual Duration Curve for LMS100 OCGT



Generator	93 MW LMS100 OCGT burning gas. Min load = 55.8 MW (60% of max).
Capacity Factor	8%
Run Hours	835 (10% of the time)
Running Load Factor	80%
Startups	101 p.a. (1 startup every 3.6 days on average).
Onload Duration	Average of 8 hours from startup to shutdown.

# Annual Duration Curve for BNE CCGT



Generator	389 MW BNE CCGT burning gas. Min load = 195 MW (50% of max).
Capacity Factor	54%
Run Hours	5,274 (60% of the time)
Running Load Factor	90%
Startups	295 p.a. (1 startup every 1.2 days on average).
Onload Duration	Average of 18 hours from startup to shutdown.

# Conclusions

- ‘Horses for courses’ – considering different scenarios leads to various least cost solutions
  - Many technologies provide comparable economic solutions
- Some technology types regularly appear in the winning enclosure
- The system can be operated securely under each scenario considered
- Provides information for informed and in-depth debate

# End of Main Presentation